


**Intertek ETL SEMKO**



**Certificate of Compliance**

This certifies that the product(s) stated below have been tested for a one-hour fire resistance rating in accordance with the following test standards: DIN 4102-2, "Fire Behaviour of Building Materials and Building Components".

**DISTRIBUTOR**

Name: **Gripple Inc.**  
Location: 1510 Hubbard Avenue  
Batavia, Illinois  
60510

**PRODUCTS**

Model: ***2mm Stainless Steel Gripple Cable & Link***

Rating Achieved: F30-A

Maximum Load: 20 kg (44 lbs)

Model: ***3mm Stainless Steel Gripple Cable & Link***

Rating Achieved: F30-A, F45-A

Maximum Load: 60 kg (132 lbs)

DATE August 2005

Per: INTERTEK TESTING SERVICES NA LTD.  
1500 Brigantine Drive, Coquitlam, B.C. V3K 7C1  
Tel: 604-520-3321